

무 대 장 치 사 양 서

| NO | DESCRIPTION | SPECIFICATION | Q'TY | LIGHTING CAPACITY (KW) | CIRCUIT | | | | MOTOR POWER (HPxP) | MOTOR CAPACITY (KW) | REMARKS |
|----|--------------------------------|---|--------|------------------------------|---------|------------------|--------|-------------|--------------------------|---------------------------|----------------------------|
| | | | | | DIMMING | REMOTE DIRECT | DIRECT | DMX LINE | | | |
| ① | ROLL PLACARD BATTEN | SOMFY 400W L = 9,000 | 1 SET | | | | | | 1/2HP x 2P | 0.4 | |
| ② | DRAW CURTAIN | MANUAL 12,000L x 3,600H | 1 SET | | | | | | | | |
| ③ | NO.1 SUSPENSION LIGHT FLY DUCT | C-TYPE 3P 30A x 16 OUT , XLR 4EA L = 9,000 | 1 SET | 8.0 | | 4 | | 2 | | | |
| | LED PAR LIGHT | COLORSOURCE PAR | 8 SET | | | | | | | | |
| ④ | NO.2 SUSPENSION LIGHT FLY DUCT | C-TYPE 3P 30A x 16 OUT , XLR 4EA L = 9,000 | 1 SET | 8.0 | | 4 | | 2 | | | |
| | LED PAR LIGHT | COLORSOURCE PAR | 8 SET | | | | | | | | |
| ⑤ | ROLLSCREEN | SOMFY 400W 300" | 1 SET | | | | | | 1/2HP x 2P | 0.4 | |
| ⑥ | 배경막 BATTEN | SOMFY 400W L = 9,000 | 1 SET | | | | | | 1/2HP x 2P | 0.4 | |
| ⑦ | APRON LIGHT FLY DUCT | C-TYPE 3P 30A x 20 OUT , XLR 4EA L = 12,000 | 1 SET | 10.0 | | 5 | | 2 | | | |
| | LED PAR LIGHT | COLORSOURCE PAR | 8 SET | | | | | | | | |
| ⑧ | NO.1 CEILING LIGHT FLY DUCT | C-TYPE 3P 30A x 20 OUT , XLR 4EA L = 12,000 | 1 SET | 10.0 | | 5 | | 2 | | | |
| | LED ELLIPSOID LIGHT | COLORSOURCE SPOT | 6 SET | | | | | | | | |
| ⑨ | NO.2 CEILING LIGHT FLY DUCT | C-TYPE 3P 30A x 20 OUT , XLR 4EA L = 12,000 | 1 SET | 10.0 | | 5 | | 2 | | | |
| | LED ELLIPSOID LIGHT | COLORSOURCE SPOT | 6 SET | | | | | | | | |
| ⑩ | HOUSE LIGHT | LED 8" 32W | 35 SET | 1.12 | | 1 | | 1 | | | |
| ⑪ | CONTROL BOARD | 1M 4F STATION, MOT : 3 | 1 SET | | | | | | | | |
| ⑫ | MAIN POWER PANEL | MAIN MCCB 4P 60AF/50AT, 2P 30AF/20AT : 30EA | 1 SET | | | | | | | | 1차측 전원 : 일반전기공사분 |
| | RELAY PANEL | ECHO RELAY PANEL FEEDTHROUGH (ERP24-FT24) | 1 SET | | | | | | | | |
| | DMX SPLITTER | 1IN 8OUT | 2 SET | | | | | | | | |
| ⑬ | HOUSE LIGHT CONTROL PANEL | SMPS 350W : 5EA, DMX DRIVER 1CH : 5EA | 1 SET | | | | | | | | |
| ⑭ | LIGHT CONTROL CONSOLE | ION 1000, FADER WING 2x20 | 1 SET | | | | | | | | |
| ⑮ | SUBCONTROL CONSOLE | 1M 4F STATION, RD : 24(A/D CONVERTER내장) | 1 SET | | | | | | | | |
| ⑯ | CONNECTOR BOX | 220V, XLR5P | 1 SET | | | | | | | | |
| ⑰ | CONTROL ROOM LIGHT | LED BULB 8W | 4 SET | | | | | | | | |
| ⑱ | CONTROL ROOM LIGHT S/W | DIMMING S/W | 1 SET | | | | | | | | |
| | TOTAL LOAD | | | 47.12 | | | | | | | |
| | DEMAND FACTOR | | | 70 % | | | | | | | |
| | DEMAND LOAD | | | 33.1 | | 24 | | 11 | | 1.2 | MAIN MCCB 4P 125AF/60AT |

PROJECT TITLE

구로구
시설관리공단
리모델링공사



이지종합건축사사무소

서울시 송파구 석촌동 277-1

TEL (02)424-5886

FAX (02)424-6774

NOTE

| | | | |
|------------------|------|-------------|----|
| 1 | | | |
| 2 | | | |
| 3 | | | |
| REV | DATE | DESCRIPTION | BY |
| 일자 DATE | | | |
| 2016.05 | | | |
| 제도 DRAWN BY | | | |
| 감토 CHECKED BY | | | |
| 승인 APPROVED BY | | | |
| 도면명 DRAWING NAME | | | |
| 무대장치 사양서 | | | |
| 축척 SCALE | | | |
| A3: 1/100 | | | |
| DRAWING NO. | | SHEET NO. | |
| L-001 | | | |